

# Fire Protection Survey Services™

2403 Fairgrounds Road  
Washago, Ontario, Canada, L0K 2B0  
Telephone: (249) 359-7231  
E-mail: [fpss@xplornet.ca](mailto:fpss@xplornet.ca) Website: [www.fpss.ca](http://www.fpss.ca)

## Fire Department Water Tanker Shuttle Accreditation

Presented To: Township of Augusta

### ACCREDITED FIRE STATIONS

Maitland Fire Station

North Augusta Fire Station

Date Test Passed: August 26, 2017

Flow Achieved: 415 I.G.P.M. 1885 LITERS/MIN.

Two (2) Hour Test Time



Signed: Peter J. Rose

Peter J. Rose, C.E.T., F.P.T.  
Senior Fire Protection Specialist  
Senior Loss Control Specialist